



Proposed Rules

Boiler and Process Heater Major Source MACT- Sec. 112

- Applicable to all boilers and indirect fired process heaters
- Located at major HAP sites
 - >10 TPY single HAP; >25 TPY all HAPs

Boiler Area Source Rule

Applicable to non-major HAP sources

Definition of Solid Waste Rule

- Determines what is solid waste for regulation under Sec.129 (CISWI)
- Or not solid waste and regulated under Boiler MACT
- Applicable to determination for all non-gaseous fuels that are non-traditional fossil fuels

CISWI Rule

• Sec. 129 replacement rule



Revised Rule- Major Source Boiler & Process Heater MACT

Proposed rule signed 4/29/2010

Issued in Federal Register on June 4, 2010

45 day comment period in proposed rule

- Notice coming this week scheduling hearings and extending comment period to 60 days
 - Comments due on all rules August 4, 2010

Final rule promulgation scheduled for 12/16/2010

Industry will request a comment extension for all 4 rules tied to a similar final promulgation date extension

Compliance date 3 years following promulgation in Fed. Reg.

- Final rule promulgation 12/16/2013 per current schedule
- One year extension per General Provisions if delays beyond control

Based on the proposal, litigation is almost certain

Hearing Schedule

Arlington, VA- June 15, 2010

- Crystal City Marriott
- 1999 Jefferson Davis Highway

Houston, TX- June 22, 2010

- Hilton Houston Hobby Airport
- 8181 Airport Boulevard

Los Angeles, CA- June 22, 2010

- Sheraton Los Angeles Downtown Hotel
- 711 South Hope Street

9:00AM until 8:00PM or later with lunch/dinner breaks Oral testimony limited to 6 minutes per commenter



Major Source Boiler/Process Heater MACT

Applies to boilers and process heaters at major sources of hazardous air pollutants.

Affects 1,600 facilities and 13,555 boilers

• about 11,500 are gas fired boilers and process heaters

Emission limits, monitoring, testing for PM, HCI, Hg, CO, dioxin/furans

Will require addition of multiple controls and complex monitoring to meet proposed limits

Limits based on fuel type for PM, HCI, Hg and by fuel type and boiler design for CO, dioxin/furan



Breadth of Applicability

Major HAP source Boiler/Process Heater MACT

- Facilities in the Phase 1 database are shown in the next 2 charts
 - Identified by NAICS Code description
 - First chart- all facilities (a facility is a plant site, each with at least one unit)
 - Second chart- facilities excluding those that have only Gas1 fired units (natural gas or refinery gas)
 - i.e., these have at least one coal, biomass, liquid, Gas 2 (other gases) fired unit
- The point is that this rule has a huge impact on a tremendous number of facilities and units spread broadly across the economy- public and private sectors

ICI Boiler Area Source rule covers even more units located at all other non-major HAP sites





Boiler/Process Heater MACT Rulemaking ICR Phase 1 Database Number of Facilities by NAICS Description (Includes Facilities That Only Have Gas1 Boilers)



Boiler/Process Heater MACT Rulemaking ICR Phase 1 Database Number of Facilities by NAICS Description (Excludes Facilities with Gas 1 Boilers Only)

Phase 1 ICR Inventory Database

Number of boilers & process heaters in non-Gas 1 subcategories

Coal	578
Biomass	420
Liquid	803
Gas 2	199
Total	2000



Existing Unit Coal Fired Boiler Emission Limits

Coal Boilers (burning at least 10% coal or petcoke)

Original Existing				
Compound	MACT Limit	Proposed Rule	Units	
PM	0.07	0.02	lb/MMBtu	
HCI	0.09	0.02	lb/MMBtu	
Hg	9E-06	3E-06	lb/MMBtu	
Dioxin (TEQ basis) (no	Stoker/grate/other	0.003	TEQ ng/dscm @ 7% O2	
limit under original	Pulverized Coal	0.004	TEQ ng/dscm @ 7% O2	
MACT)	Fluidized Bed	0.002	TEQ ng/dscm @ 7% O2	
Carbon Monoxide (no	Stoker/grate/other	50	ppm @ 3% O2 as Propane	
limit under original MACT	Pulverized Coal	90	ppm @ 3% O2 as Propane	
for existing)	Fluidized Bed	30	ppm @ 3% O2 as Propane	

Note: TSM not included in proposed rule as alternative to PM



New Unit Coal Fired Boiler Emission Limits

Coal Boilers

Compound	Original MACT Limit	Proposed Rule	Units
PM	0.025	0.001	lb/MMBtu
HCI	0.02	6E-05	lb/MMBtu
Нд	3E-06	2E-06	lb/MMBtu
Dioxin (TEQ basis) (no	Stoker/grate/other	0.003	TEQ ng/dscm @ 7% O2
limit under original	Pulverized Coal	0.002	TEQ ng/dscm @ 7% O2
MACT)	Fluidized Bed	3E-05	TEQ ng/dscm @ 7% O2
	Stoker/grate/other	7	ppm @ 3% O2 as Propane
CO (original new MACT	Pulverized Coal	90	ppm @ 3% O2 as Propane
limit of 400)	Fluidized Bed	30	ppm @ 3% O2 as Propane



Existing Unit Biomass Fired Boiler Emission Limits

Biomass Boilers

	Original Existing			
Compound	MACT Limit	Proposed Rule	Units	
РМ	0.07	0.02	lb/MMBtu	
HCI	0.09	0.006	lb/MMBtu	
Нд	9E-06	9E-07	lb/MMBtu	
	Susp burner/Dutch oven	0.03	TEQ ng/dscm @ 7% O2	
Dioxin (TEQ basis) (no	Fluidized Bed	0.02	TEQ ng/dscm @ 7% O2	
limit under original	Fuel Cell	0.02	TEQ ng/dscm @ 7% O2	
MACT)	Stoker/grate/other	0.004	TEQ ng/dscm @ 7% O2	
	Susp burner/Dutch oven	1010	ppm @ 3% O2 as Propane	
Carbon Monoxide (no	Fluidized Bed	250	ppm @ 3% O2 as Propane	
limit under original MACT	Fuel Cell	270	ppm @ 3% O2 as Propane	
for existing)	Stoker/grate/other	560	ppm @ 3% O2 as Propane	



New Unit Biomass Fired Boiler Emission Limits

Biomass Boilers

	Original NEW MACT			
Compound	Limit	Proposed Rule	Units	
PM	0.025	0.008	lb/MMBtu	
HCI	0.02	0.004	lb/MMBtu	
Нд	3E-06	2E-07	lb/MMBtu	
	Susp burner/Dutch oven	0.03	TEQ ng/dscm @ 7% O2	
Dioxin (TEQ basis) (no	Fluidized Bed	0.007	TEQ ng/dscm @ 7% O2	
limit under original	Fuel Cell	5E-04	TEQ ng/dscm @ 7% O2	
MACT)	Stoker/grate/other	5E-05	TEQ ng/dscm @ 7% O2	
	Susp burner/Dutch oven	1010	ppm @ 3% O2 as Propane	
Carbon Monoxide	Fluidized Bed	40	ppm @ 3% O2 as Propane	
(original new MACT limit	Fuel Cell	270	ppm @ 3% O2 as Propane	
of 400)	Stoker/grate/other	560	ppm @ 3% O2 as Propane	



Existing Unit Liquid Fired Boiler/PH Emission Limits

Liquid Fuel Boilers

	Original Existing		
Compound	MACT Limit	Proposed Rule	Units
РМ	NA	0.004	lb/MMBtu
HCI	NA	9E-04	lb/MMBtu
Нд	NA	4E-06	lb/MMBtu
Carbon Monoxide	NA	1	ppm @ 3% O2 as Propane
Dioxin (TEQ basis)	NA	0.002	TEQ ng/dscm @ 7% O2



New Unit Liquid Fired Boiler/PH Emission Limits

Liquid Fuel Boilers

Compound Original MACT Limi		Proposed Rule	Units
PM	new large: 0.03	0.002	lb/MMBtu
HCI	new large: 0.0005	4E-04	lb/MMBtu
Нд	NA	3E-07	lb/MMBtu
Carbon Monoxide	400	1	ppm @ 3% O2 as Propane
Dioxin (TEQ basis)	NA	0.002	TEQ ng/dscm @ 7% O2



Gaseous Fuels

Gas 1

- Natural gas and/or refinery gas
- Natural gas definition
 - (1) A naturally occurring mixture of hydrocarbon and nonhydrocarbon gases found in geologic formations beneath the earth's surface, of which the principal constituent is methane; or
 - (2) Liquid petroleum gas
 - (Note- definition does not currently include the revised NSPS definition:
 (3) A mixture of hydrocarbons that maintains a gaseous state at ISO conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 34 and 43 megajoules (MJ) per dry standard cubic meter (910 and 1,150 Btu per dry standard cubic foot).

Gas 2

· Gaseous fuels other than natural gas and/or refinery gas



Existing Unit Gas 2 Fired Boiler/PH Emission Limits

Units designed to burn other gases

	Original Existing		
Compound	MACT Limit		Units
PM	NA	0.05	lb/MMBtu
HCI	NA	3E-06	lb/MMBtu
Нд	NA	2E-07	lb/MMBtu
Carbon Monoxide	NA	1	ppm @ 3% O2 as Propane
Dioxin (TEQ basis)	NA	0.009	TEQ ng/dscm @ 7% O2



New Unit Gas 2 Fired Boiler/PH Emission Limits

Units designed to burn other gases

Compound	Original MACT Limit		Units
PM	NA	0.003	Ib/MMBtu
HCI	NA	3E-06	lb/MMBtu
Hg	NA	2E-07	lb/MMBtu
Carbon Monoxide	400	1	ppm @ 3% O2 as Propane
Dioxin (TEQ basis)	NA	0.009	TEQ ng/dscm @ 7% O2



Existing and New Gas 1- Natural Gas/ Refinery Gas Fired Boilers/Process Heaters

No emission limits

Annual tune-up required

- Also for units <10MMBtu/hr firing any fuel
- Also for metal processing furnaces (any gaseous fuels)
- Requirements are prescribed- minimize CO



Compliance Methods

PM, HCI, Hg, CO

- Annual emission testing- 4 hour minimum run time for all
 - Triennial testing if 3 years average \leq 75% of limit
 - Percent was not in prior rule

Dioxin/Furan

Annual emission testing

PM CEMS for coal, biomass, residual oil units > 250MMBtu/hr CO CEMS for units > 100MMBtu/hr

• 30 day rolling average basis



Health Based Compliance Alternative

Prior rule included for HCI and for Mn within TSM

Proposal

- Does not include HBCA approach in the rule
- Does not provide a TSM alternative to PM limit
 - Therefore, no application for HBCA to Mn

Preamble includes discussion of health-based approaches

- EPA may be amenable to a health based off-ramp for HCI only
 - May need to consider HCI, CI2, HCN emissions
- EPA not amenable to Mn approach



Continuous Compliance with Emission Limits

Fabric Filter Control

- Bag leak detection system with alarm ≤ 5% operating time per 6 months OR
- Opacity per COMS \leq 10% on daily block average basis

ESP

- Opacity per COMS \leq 10% on daily block average basis
- Maintain 12 hour block average secondary current and voltage or total power input at or above level during performance test (for units with wet scrubbers)

Wet scrubber

- Maintain 12 hour block average pressure drop and liquid flow rate at or above level during performance test
- Maintain 12 hour block average pH at or above level during performance test

Dry Scrubber or Carbon Injection

Maintain 12 hour block average minimum sorbent or carbon injection rate at or above level during performance test

Fuel pollutant content

 Keep monthly records of fuel use- only burn fuel types and mixtures used to demonstrate compliance

Emissions Averaging

Included in the rule as a compliance option for PM, HCI, Hg EPA intention to apply a 10% discount factor

• Discount factor was not in prior rule

Uses monthly compliance for first 12 months and then 12 month rolling average methodology



Fuel Analysis for Compliance

Can use fuel analysis for compliance with HCI, Hg emission limits based on CI, Hg in fuel

• Very low limits make this very limited usefulness



SSM

No specific provisions for SSM

EPA contends emissions limits cover and allow for startup and shutdown periods

 Examples- daily block average for opacity; 12 hour block average operating limits; 30 day rolling average CO limit

EPA says malfunctions should not occur

• If they do and > limits, it is a deviation

No SSM Plan



Overall Major Source Requirement for Existing Boilers

One time energy assessment

 an in-depth assessment of a facility to identify immediate and long-term opportunities to save energy, focusing on the steam and process heating systems which involves a thorough examination of potential savings from energy efficiency improvements, waste minimization and pollution prevention, and productivity improvement

This is obviously an extension far beyond CAA authority into the entire plant



Major Concerns/Problems



Main Industry Concerns

Lack of health based compliance option

- Need option of risk analysis for HCl as a minimum
 - Many potential ways to address
- No TSM alternative standard to PM
 - Mainly an issue for biomass units
 - Potential TSM limit if follow EPA methodology below
 - Discuss further later

Results of analysis of TSM10 floor using the top PM performers:

Top performers based on the ERG MACT Floor memo

				Increased
Category	Proposed PM	Old TSM	New TSM10	Stringency
Coal	0.02	0.001	9.00E-04	1.1
Biomass	0.02	0.001	2.00E-04	5.0
Liquid	0.004	NA	2.00E-05	NA
Gas2	0.05	NA	3.00E-05	NA
All units lb/MMBtu				



Main Industry Concerns

Achievability of limits

- Coal/biomass combination boilers can't meet coal CO limits
- Ultra low CO limits for liquid and process gases
 - Landfill gas included with other/process gases
- Not sure how to meet dioxin limits
- Very low Hg/HCI limits
- No facilities meet all the limits, even the few with controls
- New source limits will discourage (eliminate?) new boiler construction

Cost

- EPA estimates almost \$10Billion capital cost
 - Easy to estimate 2-3 x that amount



EPA has Underestimated Boiler MACT Costs

RIA indicates that capital cost is \$9.5 Billion

AF&PA/CIBO conservative analysis based on EPA database shows capital cost of at least \$21B for all non- Gas1 units

Other estimates close to \$50 Billion Pulp and Paper: \$4 B Chemical: \$4 B Utilities: \$3.5 B Wood Products: \$2 B Food Mfg: \$1.6 B Primary Metal: \$1 B Furniture: \$350 M

Dozens of other sectors



Boiler MACT Costs for Forest Products

<u>HAPs/ Surrogates by</u> <u>Fuel type</u>	<u>PM/metals</u>	Carbon Monoxide (CO)	<u>Mercury/ Dioxin</u>	<u>HCl</u> (acid gases)
Biomass \$3.3B	\$1341M	\$74M	\$308M	\$1542M
Coal \$1.9B	\$570M	\$260M	\$131M	\$911M
Oil \$1.1B	\$421M	\$144M	\$68M	\$499M
Gas2 \$31M	\$12M	\$4M	\$2M	\$13M
Total cost: \$6.3 billion	\$2.34B	\$482M	\$509M	\$2.97B



Boiler MACT Controls Capital Costs for Chemical Manufacturing

<u>HAPs/</u> Surrogatos by	PM/metals	<u>Carbon</u> Monoxido (CO)	Mercury/ Dioxin	HCI
<u>Sunogates by</u> Fuel type				(aciu gases)
Coal \$910M	\$200M	\$150M	\$80M	\$480M
Oil \$940M	\$300M	\$175M	\$85M	\$375M
Gas2 \$1.9B	\$700M	\$250M	\$130M	\$800M
Total cost: \$3.8 billion	\$1.2B	\$574M	\$296M	\$1.7B



Main Industry Concerns

Data being used to develop the standard

- Small number of boilers in subcategory in some cases
- Acknowledgement of emissions variability
- Need different statistical approach
- Extensive non-detect data drives limits very low
- Data must undergo through quality review

Natural gas/refinery gas fired units – work practices do make sense

- If EPA doesn't defend this approach, then \$50 B higher compliance cost to meet their potential floor limits!
- Most Gas 2 units should be treated similarly
- However, there are issues with their work practice approach as well



Natural Gas/Refinery Gas Control Cost Savings Using Work Practice Approach

<u>Sector</u>	<u>PM/metals</u>	<u>Carbon</u> <u>Monoxide (CO)</u>	<u>Mercury/ Dioxin</u>	<u>HCI</u> (acid gases)
Chemical Manufacturing \$7.8B (890 boilers in database)	\$3B	\$873M	\$436M	\$3.5B
Forest Products \$3.4 billion	\$1.3B	\$384M	\$191M	\$1.5B
All Industry: >\$50 billion	\$19.5B	\$5.8B	\$2.9B	\$23B



Achievability of Limits

Actual real- world boilers cannot meet all limits

- Limits on a pollutant-by-pollutant basis
- MACT being driven by math, not technology
- Consider more subcategories limited use, wet/dry biomass, coal rank, large size cutoff (e.g., raise to 30 MM Btu/hr)
- Combination fuel boilers not necessarily representative of the subcategory
- New Source MACT limits are so low that new boilers will be hard to build
 - driven by single data point at limit of detection
 - RIA predicts ZERO new biomass and coal fired boilers



Data Issues

Not enough consideration of variability

- CO using only 3-run stack tests, even though CO highly variable for most boilers
- No fuel variability adjustment for some fuels/pollutants

1 or 2 boilers at non-detect drive dioxin trying to represent hundreds of boilers

Little liquid data overall – very low limits

Need a better statistical approach given the data set doesn't represent the population and contains data skewed toward top performers



Variability Critical



Fuel Content Variability Important to Consider



All Coal Mercury Run Data





Hg Coal Floor Data- Top Performers



All Biomass Mercury Run Data



Hg Biomass Floor Data- Top Performers



QU POND.

All Gas 2 Mercury Run Data



OUPOND

Hg Gas 2 Floor Data- Top Performers



6/16/2010

All Stoker Coal Dioxin/Furan Run Data





Stoker Coal D/F Floor Data- Top Performers





All FBC Coal Dioxin/Furan Run Data



47

OUPINT

FBC Coal D/F Floor Data- Top Performers



All Liquid Dioxin/Furan Run Data



QU POND.

Liquid D/F Floor Data- Top Performers



All Gas 2 Dioxin/Furan Run Data



Gas 2 D/F Floor Data- Top Performers



Liquid CO vs NOx for All Runs





Concerned Trade Groups- Working Together

American Forest & Paper Association American Chemistry Council American Coke & Coal Chemicals Institute **American Home Furnishings Alliance** American Iron and Steel Institute American Municipal Power, Inc. American Petroleum Institute **American Sugar Alliance** American Wood Council Alliance of Automobile Manufacturers **Biomass Power Association Brick Industries Association Composite Panel Association Corn Refiners Association Council of Industrial Boiler Owners**

Edison Electric Institute National Association of Manufacturers National Cotton Ginners Association National Lime Association National Oil Recyclers Association National Oilseed Processors Association **National Petrochemical & Refiners** Association **Ohio Municipal Electric Association** Pellet Fuels Association **Rubber Manufacturers** Association Society of Chemical Manufacturers and Affiliates **Treated Wood Council** U.S. Chamber of Commerce



Path Forward- all four rules

Individual trade association review and comment development

• Tremendous amount of information and data

Also joint comments on common issues

Leveraging resources

- URS contracts for data handling, statistics, and some comment development
- AECOM for HBCA, modeling, and toxicology issues
- Others

Major overall effort

Meetings with OMB prior to signing resulted in some positive changes to the proposal

Also pressuring EPA with letters from Congress pressing for flexibility

Comments will lay the groundwork for litigation



CIBO Comment Preparation Discussion

Will review main comment concepts thus far separately



Solid Waste Definition Proposed Rule Fuel Flowchart



Flow Chart for Determining Whether Non-Hazardous Materials Used as Evel In Combustion Units are Solid Waste Solid Waste Definition Proposed Rule Ingredient Flowchart



Flow Chart for Determining Whether Non-Hazardous Secondary Material Ingredients Burned In Combustion Units are Solid Wastes