



PRESENTATION TO



Energy Efficiency Options for Industrial Plants






Why Energy Efficiency?

IBO's can get ahead of curve


- **Emissions compliance**
 - degrades efficiency/increases auxiliary loads
- **GHG Regulations**
 - Efficiency/Process/Equipment Performance Improvements
 - Boiler tuning/furnace exit gas heat recovery
- **CO2 Registries**
 - Identifies potential regulatory/environmental targets
- **DOE**
 - Efficiency is cheapest way to reduce CO2 emissions
- **Efficiency 1-10%; MA: Efficiency/Renewable offsets**



Efficiency Improvement The Process

- ◆ Define Objectives
- ◆ Review Design Basis
- ◆ Establish Baseline
- ◆ Assess Condition
- ◆ Interview Plant Personnel
- ◆ Benchmark & Evaluate
- ◆ Identify Improvements
- ◆ Rank Economically
- ◆ Plan & Implement
- ◆ Validate & Verify
- ◆ Monitor & Follow-up






Where do we start?

Review Design Basis/Establish Baseline

Engineering Evaluation


- Plants operating for many years with staff turnover
- Plant modifications may not have been integrated
- Current operations to be optimized with design
- Plant configuration control brought up to date
- New perspectives bring potential energy savings



Unit Performance Testing

- VWO Test with Senior Consultant in Control Room
- Move unit to determine equipment constraints
- Identify suspect instruments by closing heat balance






Where are we now?


Energy Assessment

- Engineering/Economic Evaluation
- Determine Major Equipment Constraints
- As-Found vs. Design Heat Balance comparison

Unit #1 Energy Losses

Design Heat Rate 8960 BTU/kWhr
As Found Heat Rate 9602 BTU/kWhr





Asset Optimization Performance – Phase I

BOP CCR: Capacity Constraint Release (current configuration)


Step 1: Identify Low Hanging Fruit

- Collect VWO Operating Data, Power Uprate Heat Balance
- Interview plant management & operations staff
- Establish current baseline & model systems
- Lighting/HVAC/Motor/VSD/automation efficiency upgrades

Step 2: Mitigate Capacity Constraints

- Heat Rate conclusions (quantifies cost of production impacts)
- Develop solutions to unlock constraints
- Identify cost reduction opportunities
- Develop budgetary costs/predicted MW regains

Result: Actionable NPV specific recommendations



Asset Optimization Performance – Phase I

BOP LF: Limiting Factors (support of prime mover uprate)


Step 1: Assessment of Current Operating Performance

- Collect VWO Operating Data, Power Uprate Heat Balance
- Interview plant management & operations staff
- Establish Current Baseline
- Model mechanical and electrical systems

Step 2: Assessment & Release of BOP Limiting Factors


- Identify equipment/systems that prevent achieving full uprate
- Develop solutions to unlock constraints
- Develop budgetary costs/predicted MW regains


Result: Actionable NPV specific recommendations



BOP CCR/LF Analysis

- **Thermal Cycle Modeled in Gate Cycle**
 - Establish New Flow/Pressure/Temp Conditions at Components







BOP CCR/LF Analysis

- **Electrical System Modeled in ETAP**
 - **Load Flow Analysis**

One-Line Diagram - Brandon Shores Unit 1 R1 (Load Flow Analysis)





*Asset Optimization
Improve Performance*



Midwestern Industrial Power Facility


- Installing APCS for SOx Reduction
- Requests Boiler/Turbine/BOP optimization study to determine uprate capacity for three existing 144MW units

The SAVE™ Solution:

- Optimized Plant Retrofit (OPR) Study addresses uprating of boiler and turbine
- Debottlenecking approach analyzes BOP system and equipment constraints

Results:

- 20% uprate (w/HP retro) and 10% uprate (w/o HP retro)
- BOP constraints identified and mitigation plan developed



*Asset Optimization
Improve Performance*



Industrial Power Facility


- Plant exhibiting high reliability
- Identified need to improve heat rate
- Target underperforming equipment/systems

The SAVE™ Solution:

- Integrated steam plant analysis
- Identify, assess and mitigate BOP system and equipment constraints

Results:


- Small capital recommendations generated \$2.2M NPV
- Included installing condensate return system, FWH



*Asset Optimization
Improve Performance*

Industrial Power Facility

- Combined cycle generation
- Identified need to improve heat rate
- Focus on power block




The SAVE™ Solution:

- Integrated plant analysis
- Assessed third party financial contracts

Results:

- Recommendations identified ~\$4.5M in annual savings
- Included installing unit controls and plant-wide EMS



*Asset Optimization
Improve Performance*



AES Warrior Run (180MW CFB)


- Client requested assistance in recovering 600 BTU/kWh degradation from initial as commissioned plant heat rate

The SAVE™ Solution:

- Energy Assessment Approach
- Evaluated current VWO performance against design basis
- Generated Operational, Maintenance and Capital project recommendations

Results:

- 40-60% of heat rate degradation recovered
- Capital project: condensate to dry limestone < 2yr payback



*Asset Optimization
Improve Performance*



Eastern Supercritical PC Units

- Slated for divestiture, investments lagged
- Older plant beyond original design life

The SAVE™ Solution:


- Integrated Reliability/Efficiency Assessment

Recommendations:

- Cycle analysis estimated 1000BTU pick-up
- Recover > 100,000MWH of lost availability
- Developed critical systems equipment plan
- Identified key programmatic issues

Results:

- \$21M NPV in Efficiency Improvements
- \$3M in Annual Availability Recovery



*Asset Optimization
Improve Performance*



MidAmerican Energy Louisa 1 (758MW)

- Installing APCS for SOx Reduction
- Requests IP/LP Retrofit and Boiler/BOP optimization study to recover aux load

The SAVE™ Solution:

- IP/LP retrofit
- Enhanced Optimized Plant Retrofit (OPR) Study addresses boiler issues and upgrades
- BOP analysis identifies CT/CW limitations and back-pressure improvements

Results:

- Total uplift predicted to be ~50-59MW depending upon season
- Enhanced OPR added ~30-40MW to the IP/LP only case



dibo

THANK YOU FOR YOUR TIME AND ATTENTION!

**Tony Munisteri, P.E., C.E.M.
Director, Asset Optimization**

P: (631) 420-3220

F: (631) 420-3206

C: (516) 297-4019

anthony.munisteri@us.sigenergy.com