

Logistics
> Copy of presentation will be emailed to attendees after the presentation
> Questions
 Submit questions via WebEx chat
 Submit questions via email
 Trinity will followup on questions post-presentation
> Discussion
 Lines are muted during main part of presentation
 At end, can un-mute individually for questions
Press *6 to un-mute
 To mute again, press *6 again



















- > September 20, 2013 new proposed rule signed
- > Not yet in Federal Register anticipated January 2014
- > Major revisions to 2012 proposal
- EPA also announced plan to rescind the 2012 proposal in entirety via a separate Federal Register notice the same day as the new proposed rule

Gnsultants









- > Statute [§169(a)(3)] mandates that BACT can be no less stringent than any standard under §111
- > EPA position is that NSPS set a BACT "floor" once final (a proposed NSPS does not set the floor)
- > EPA position is that the proposed NSPS
 - Only sets a floor for new EGUs
 - Does not set a floor for modified or reconstructed EGUs
 - Basis is that under the proposed NSPS, an affected facility is only a new EGU

Gnsultants





















- 1. Stationary combustion turbine
- 2. Design heat input > 250 MMBtu/hr
- Combusts fossil fuel > 10% of average annual heat input on 3-year rolling average basis
- 4. Combusts over 90% natural gas on a heat input basis on a 3-year rolling average basis
- Constructed for purpose of supplying, and supplies, 1/3 or more of potential electrical output and more than 219,000 MW-hrs to a utility distribution system on 3-year rolling average basis





Emission Limits - Summary									
CO ₂ - Ib/MW-hr									
	Unit Type	12-month avg	84-month avg						
	Boiler	1,100	1,050						
	IGCC	1,100	1,050						
	Turbine <=850 MMBtu/hr	1,100							
	Turbine >850 MMBtu/hr	1,000							
> All limits on gross power basis									
> EPA is requesting comment on a									
net power approach with different									
numerical limits (higher numerically)									
				Gnsultants					

Emission Limits - Summary								
Unit Type	CO ₂ Ib/MW-hr	Heat Rate HHV - Gross (Btu/kW-hr)		$T_c - 80 F$ $n_{th} - 67\%$				
Boiler/IGCC - Bituminous Boiler/IGCC - Sub-Bituminous Turbine <=850 MMBtu/hr Turbine >850 MMBtu/hr	1,100 1,100 1,100 1,000	5,349 5,135 9,411 8,555	64% 66% Not fe 36% Not fe 40% simple	asible w/o CCS				
Turbine >850 MMBtu/hr 1,000 8,555 40% simple for simple cycle One of the most efficient simple cycle turbines GE LMS100 – design heat rate (HHV) ~ 8,500 Btu/kW-hr Efficient but more typical turbines GE LM6000 – design heat rate (HHV) ~ 9,400 Btu/kW-hr Efficient but more typical turbines GE LM6000 – design heat rate (HHV) ~ 35% TinityA								









Boilers - CCS Cost Impacts

Moreover, even if requiring CCS adds sufficient costs to prevent new coal-fired plants from constructing in a particular part of the country due to lack of available EOR to defray the costs, or, in fact, from constructing at all, a new NGCC plant can be built to serve the electricity demand that the coal-fired plant would otherwise serve. Thus, the present rulemaking does not prevent basic electricity demand from being met, and thus does not have an adverse effect on the supply of electricity.

...the EPA is authorized to promulgate standards of performance under CAA § 111 that may have the effect of precluding construction of sources in certain geographic locations

Geographic Restrictions ??

... in 1970, Congress designed section 111 to require uniform national controls for large industrial facilities, while recognizing that those facilities could not necessarily construct in every place in the country.

Although at the time, Congress expected that the reason why some sources would not be able to locate in certain places was related to local air quality concerns, <u>if the</u> reason turns out to be related to the emission limits that the EPA promulgates under section 111, that should not be viewed as inconsistent with congressional intent for <u>section 111.</u>

A <u>large</u> jump in logic that could be very impactful in some areas



















