

trinityconsultants.com

New Source Boiler MACT Compliance Case Study

Council of Industrial Boiler Owners Technical Focus Group Mtg. Arlington, VA♦ December 3, 2013 Dale Overcash, Principal Consultant

Project Scope

- > Two Small Biomass Boilers at a Major HAP Source (< 50 MMBTU/hr)</p>
- > Time Frame Early 2011
- > Regulations in a state of flux
- > Controls
 - Baghouse
 - Sorbent injection



Permitting & Compliance Issues

- > NSR Issues
- > 112(d) or 112(j)
 - EPA issues final rule March 21, 2011
 - EPA stay May 16, 2011
 - Which rules are in place?
 - Draft December 2011 rule
 - New Provisions
 - DC District Court removes stay January 9, 2012
 - Effective dates of rules?



Emission Limits

> Moving Target

> March 21, 2011 - January 30, 2013

- Table 12 Limits:
 - PM: 0.008 lb/MMBtu heat input
 - HCL: 0.004 lb/MMBtu heat input
 - CO: 560 ppm by volume
 - Hg: 3.50 E-06 lb/MMBtu heat input
- > January 31, 2013
 - Table 1 Limits:
 - PM: 0.03 lb/MMBtu heat input
 - HCL: 0.022 lb/MMBtu heat input
 - CO: 620 ppm by volume
 - Hg: 8.0 E-07 lb/MMBtu heat input



Data Analysis for NESHAP Compliance

- > Engineering Test Provided Clues
 - With extremely tight limits in 2011, compliance was a concern
 - Engineering testing provided preliminary data for compliance (with which limits??)
 - Data for HCl control
 - Data provided indication of required controls



Monitoring Options

- > PM BLDS (5% alarms) or COMS (10% opacity)
- > CO
 - > O₂ CEMS (Per March 2011 final Rules)
 - CO CEMS, or O₂ analyzer (oxygen trim system) (Per Dec. 2011 Proposed Rules)
 - CO and O₂ CEMS, or O₂ analyzer (oxygen trim system) (Per Jan.
 2013 Final Rules)
 - > CEMS Citing Issues
- > Boiler Load logically steam
- > HCl & Hg fuel sampling or performance testing



Initial Compliance

- > One Fuel
 - Performance Testing
- > Two or more fuels
 - Performance Testing and
 - Fuel Analysis
- Compliance can be documented with either
 Performance Testing or Fuel Analysis for
 certain pollutants



Fuel Sampling

- > Two different fuels (biomass) proposed for boiler
- > Fuel sampling for wood TSM, HCl, Hg
- > July 2012 Results were not favorable Met Hg not HCl (March 2011 rule) and met HCl and not TSM and Hg (Jan. 2013 rule).
- February 2013 Results were not favorable -met HCl and not Hg (Jan. 2013 rule). TSM unlikely
- > Due to the amount of effort required for fuel testing and the variability of results, fuel testing was undesirable
- > Annual source testing



Testing

- > Emission Limit Compliance
 - Annual Testing for
 - ♦ PM, CO, HCl, & Hg
 - If 2 consecutive years are less than 75% of EL, can reduce testing to once per three years
 - If above 75%, must test annually (until previous requirement is met)
- > Operating Limits Compliance
 - Verify, or potential for, resetting Operating Limits each time the facility tests



Establish Operating Limits

> Moving Target

> March 21, 2011 - January 30, 2013

- Minimum Oxygen Content set at lowest hourly average from most recent performance test
- Maximum Operating Load set at 110% of the <u>average</u> operating load from most recent performance test
- Operate a BLDS that alarms no more than 5% of the operating time during the 6 month period

> January 31, 2013

- Minimum Oxygen Content set at lowest hourly average from most recent performance test
- Maximum Operating Load set at 110% of the <u>highest hourly</u> average operating load from most recent performance test
- Operate a BLDS that alarms no more than 5% of the operating time during the 6 month period



Data Required to Analyze Compliance for Oxygen and Steam Load

- > 15 minute data collection for oxygen and steam load
 - Approx. 17,500 data points/operating parameter/boiler
 - Potentially 17,500++ data points since most analyzers collect data more often than 15 minutes
- > Missing 15 minute data = deviation
- > OLs were 12 hour block avgs., now 30 day rolling avgs.
 - Use and Average all available data
- > Differences between block & rolling avgs. no real benefits ... except for missing data



Data Required to Analyze Compliance for BLDS

- > Setup BLDS per §63.7525(j)
- > Analyze data per §63.7540(a)(7)
 - Initiate corrective action within 1 hr of alert
 - Record date, time and duration of each alert
 - Record time each corrective action was initiated and completed along with cause and action taken
 - If inspection of FF indicates no need for corrective action, alert time is not counted
 - If corrective action is required, each alert is counted as
 1 hr unless CA takes longer than 1 hr (then actual time)
 - Record % of operating time in each 6 month for alerts



Semiannual Reports - Overview

- > Contained within §63.7550 (a) (e)
- > Massive reports
- > Large amounts of data to review (10 MB files not uncommon)
- > Deviations for missing data likely
- > Begin working on them at the beginning of the month they are due
- > Boiler fluctuations have negative affects on meeting operating limits



SAR - General Content

- > Company Administrative Information
- > Boiler (or PH) Description
- > ELs and OLs (could be more than one set of OLs)
- > Boiler operating time
- > Mass of each fuel burned in each boiler
- > Performance testing information on occurrence of testing (but most test data is submitted in NOCS)
- > Types of fuels burned, including new or future fuels
- > Fuel analysis information



SAR - General Content - 2

- > Deviations from EL and OL
- > Deviations from monitoring requirements (missing 15 minute data) and CMS (any CMS) out of control data
- > Malfunctions of affected source, APCD, or CMS
- > Tune-up information
- > Emission averaging
- > CEMS and CPMS data
- > RO certification statement



SAR - Deviation Reporting (not using a CMS)

- > Deviations from EL or OL
 - Not using a CMS for compliance
 - Example source test results
 - Deviations Reporting
 - Description of deviation (such as failed test for X pollutant)
 - Number, duration, cause and corrective action
 - Explanation of a deviation during a performance test



SAR - Deviation Reporting (using a CMS)

- > Deviations from EL, OL, & Monitoring Req. (MR)
 - CMS Generally applies to OL & MR
 - Deviations Reporting
 - Date, time, and description of deviation (such as exceed OL or missing 15 minute data)
 - Date and time CMS was inoperative (missing 15 minute periods)
 - Date and time CMS was out of control
 - Date and time each deviation started and stopped
 - Summary of total duration of the deviation during the reporting period and the total duration as a percent of the total source operating time during the reporting period



SAR - Deviation Reporting (using a CMS) - 2

Deviations Reporting

- Characterization of total duration of deviations during the reporting period into those due to equipment problems, process problems, other known causes, and other unknown causes
- Summary of total CMS downtime during the reporting period and total duration of CMS downtime as a percentage of total source operating time during the reporting period
- Description of source from which there was a deviation
- Changes to any CMS, processes, or controls since the last reporting period for which there was a deviation



Other Reporting Requirements (see §63.7750(h))

- > The following reports/results must be submitted to EPA's WebFIRE database
 - Performance test results (within 60 days)
 - Fuel analyses (within 60 days)
 - Compliance reports (SAR) required by §63.7750(b)
- > CEMs data (within 60 days) to EPA's Central Data Exchange



Other Reporting Requirements - 2 (see §63.7750(h))

- > All reports required by Table 9 must be submitted electronically using CEDRI that is accessed through EPA's Central Data Exchange at the time the report is due; or
- > Must be sent to the EPA Administrator via mail if electronic submittal is not available



Lessons Learned

- > Understand how to operate the boilers to set OLs that you can meet
 - Dial the boiler in to get lowest O₂ value with maximum steam flow
 - Ensure boiler and controls are operating efficiently
- > Conduct engineering tests
- > QA/QC data collection systems
 - Understand shortcomings and constraints of your systems
 - Can you collect and average data?



Compliance Concerns

- > How are deviations going to be handled?
- > What is an acceptable level of OL deviations?
- > What is an acceptable level of missing data deviations?



Questions & Discussion



Trinity Consultants One Copley Parkway, Suite 310 Morrisville, NC 27560

Dale Overcash, P.E. dovercash@trinityconsultants.com (919) 462-9693



Environmental solutions delivered uncommonly well